



भारतीय प्रौद्योगिकी संस्थान गुवाहाटी

Indian Institute of Technology Guwahati

गुवाहाटी - 781 039, असम

Phone: (0361) 2582061, 2582075 Fax: (0361) 2692771

Infrastructure, Planning and Management(IPM)
अवसंरचना, योजना एवं प्रबंधन (आई पी एम) अनुभाग

Date: 04/04/2022

CORRIGENDUM

Name of Work: Augmentation of HVAC Plants in IIT Guwahati with 600TR centrifugal chiller and associated works


NIT No.: IITG/IPM/NIT/C/2021/20 Dated: 22.02.2022

Following corrections were made in the uploaded tenders (Financial Bid) of the above said work:

1. The item no. 20 of Financial Bid has been revised as follows and to be included in the financial bid of the tender replacing the earlier one. The revised clause is as follows:

In the existing Tender	To be read as
<p>Sl. No. 20 of Financial-Bid Configuration of Panel no. 1 1 No main incomer (1600 Amp) along with C.T., Selector Switch,0-500 volts Voltmeter with SS with control fuses, 0-1500 amp Ammeter with SS, Phase Indicating Lamps with control fuses, AI Busbar , 2 Nos out going feeder (600 Amp) for Water Cooled Centrifugal Chiller, 3 Nos. Star-Delta starter for primary Chilled Water Pumps (as per Sl. No. 2 (a) of Financial Bid),3 Nos. VFD starter for secondary Chilled Water Pumps (as per Sl. No. 3 (a) of Financial Bid), 3 Nos star-delta starter for Condenser Water Pumps (as per Sl. No. 4 (a) of Financial Bid) and 1 Nos star-delta starter feeder for Cooling Tower fan drive motor.</p>	<p>Sl. No. 20 of Financial-Bid Configuration of Panel no. 1 1 No main incomer (1600 Amp ACB) along with C.T., Selector Switch,0-500 volts Voltmeter with SS with control fuses, 0-1500 amp Ammeter with SS, Phase Indicating Lamps with control fuses, AI Busbar , 2 Nos out going feeder (600 Amp MCCB) for Water Cooled Centrifugal Chiller, 3 Nos. Star-Delta starter for primary Chilled Water Pumps (as per Sl. No. 2 (a) of Financial Bid),3 Nos. VFD starter for secondary Chilled Water Pumps (as per Sl. No. 3 (a) of Financial Bid), 3 Nos star-delta starter for Condenser Water Pumps (as per Sl. No. 4 (a) of Financial Bid) and 1 Nos star-delta starter feeder for Cooling Tower fan drive motor.</p>

2. Bidders are requested to submit their bids as instructed above.
3. All other items and terms & conditions will remain same.


HOS (IPM)
S. S. Saha